

## Environmental Services Analysis Report - Final

<b>Invoice Number:</b> 2187681	<b>Collected Date:</b> 19-Jun-2023 9:00 AM
<b>Sample Location:</b> Public Well	<b>Received:</b> 21-Jun-2023 10:47 AM
<b>Collected by:</b> Steve Nasby	<b>Reported:</b> 22-Jun-2023 8:54 AM
<b>Premise #:</b>	<b>Water Source:</b> Well

<b>Submitted By:</b> KIVIMAA VILLAGE OF MOONLIGHT BAY BOX 120 LIVELONG, SK S0M 1J0	<b>Invoice:</b> KIVIMAA VILLAGE OF MOONLIGHT BAY BOX 120 LIVELONG, SK S0M 1J0
---	--

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

**Submitter Phone Number:** 306-845-3336      **Emailed results to:** rvkmb@littleloon.ca

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	<b>Saskatchewan Health Authority c/o Finance 2180 23rd Avenue Regina, Saskatchewan S4S 0A5</b>	Total Fees (including GST) <span style="float: right;">23.00</span>  Tax Summary <span style="float: right;">1.10</span> G.S.T. (reg # 89583 0180 RT001)
--	--	---

Amount Received: (Mastercard) 23.00

Refund to be issued by the Department of Finance.

<b>Balance</b>	<b>\$0.00</b>
----------------	---------------

**Contact Us:**

*Result Interpretation:* Please contact your Prairie North Public Health Officer at: (306) 446-6400  
*Billing Inquiries:* Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:                                      Total Chlorine:                                      Turbidity: