

Environmental Services Analysis Report - Final

Invoice Number: 2183436	Collected Date: 30-Jan-2023 5:00 PM
Sample Location: Public Well	Received: 01-Feb-2023 10:12 AM
Collected by: Steven Nasby	Reported: 02-Feb-2023 8:32 AM
Premise #: 10222	Water Source: Well

Submitted By:	Invoice:
KIVIMAA VILLAGE OF MOONLIGHT BAY BOX 120 LIVELONG, SK S0M 1J0	KIVIMAA VILLAGE OF MOONLIGHT BAY BOX 120 LIVELONG, SK S0M 1J0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-845-3336 **Emailed results to:** rvkmb@littleloon.ca

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Saskatchewan Health Authority c/o Finance 2180 23rd Avenue Regina, Saskatchewan S4S 0A5	Total Fees (including GST)	23.00
		Tax Summary	1.10
		G.S.T. (reg # 89583 0180 RT001)	
		Amount Received: (Mastercard)	23.00

Refund to be issued by the Department of Finance.

Balance	\$0.00
----------------	---------------

Contact Us:

Result Interpretation: Please contact your Prairie North Public Health Officer at: (306) 446-6400
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: Total Chlorine: Turbidity: