

# Saskatchewan Health Authority

## Public Water - Public Water Supply

Inspected by: Stephen Clarke

Saskatchewan Health Authority

(306) 446-6400

101-11427 Railway Ave

North Battleford SK S9A 3G8

Canada

<b>Mail To:</b> Resort Village of Kivimaa Moonlight Bay  PO Box 120 Livelong SK S0M 1J0 CANADA <b>Attention:</b> Resort Village of Kivimaa Moonlight Bay  <b>Facility Inspected:</b> Kivimaa Public Well, 010222 Resort Village of Kivimaa Moonlight Bay (306) 845-3336	<b>Inspection Date:</b> 30-Mar-2023 15:15  <b>Site Address:</b> Kivimaa Drive Resort Village of Kivimaa Moonlight Bay SK S0M 1J0 Canada  <b>Phone Number:</b> (306) 845-3336 <b>Fax Number:</b> (306) 845-3686 <b>Email:</b> rvkmb@myaccess.ca <b>Violations:</b> 0
<b>Facility Type:</b> Public Water, Public Water Supply <b>Re-inspection Priority:</b> Low <b>Delivery Method:</b> Email <b>Certified Professionals:</b>	
<b>Inspection Type:</b> Routine <b>Inspection Reasons:</b> Compliance	
<b>Opening Comments and Observations:</b> Inspection conducted after making a call to the number of file and receiving the hours of operation for the town administration being Tuesdays and Wednesdays. While onsite, the PHI was unable to find a maintenance worker, such as Chris M from the previous inspection, Inspection conducted a the public well house.	

No = Not In Compliance N/O = Not Observed Yes = In Compliance N/A = Not Applicable

### Water

- |  |     |
|--|-----|
| 1. Water Source  | Yes |
| 2. Sampling  | Yes |
| <b>Sample results posted on wall in fill station. Last sample sent in 30 January 2023 and it is within compliance. Please continue to ensure that the 90 day limit is adhered to for bacteriological sampling.</b> |     |
| 3. Notification  | Yes |
| 4. Treatment   | Yes |
| Readings Taken:  |     |
| - 9:03 AM - Turbidity testing 1: 0.84NTU   |     |
| - 9:03 AM - Turbidity testing 2 : 0.97NTU  |     |
| 5. Treatment/Testing Equipment   | N/A |

Kivimaa Public Well (Public Water Supply) [010222]

Facility Contact: Resort Village of Kivimaa Moonlight Bay [7484]  
Facility Address: Kivimaa Drive, Resort Village of Kivimaa Moonlight Bay SK S0M 1J0 Canada  
Completed: 30-Mar-2023 15:15

- 6. Storage & Handling of Chemicals N/O  
 During the inspection, the PHI notes that there is a beeping/alarm sound present in the fill station behind the locked door. Please investigate.
- 7. Records Yes
- 8. Cleaning and Maintenance Yes  
 The fill station has been cleaned. Corrected from last inspection.

Actions Taken

Closing Comments:

No signature could be acquired during inspection.

Received By:



Inspector:

Resort Village of Kivimaa Moonlight Bay

Stephen Clarke, Public Health Officer