Saskatchewan Health Authority

Roy Romanow Provincial Laboratory
Environmental Services

5 Research Drive
Regina, Saskatchewan
S4S 0A4

(306) 787-7138 / (306) 787-3140

Environmental Services Analysis Report - Final

Invoice Number: 2193542
Sample Location: Public Well
Collected by: Steve N.
Premise #:

Collected Date: 02-Jan-2024 8:30 AM
Received: 03-Jan-2024 8:50 AM
Reported: 04-Jan-2024 9:40 AM
Water Source: Well

Submitted By:
KIVIMAA VILLAGE OF
MOONLIGHT BAY
BOX 120
LIVELONG, SK
S0M 1J0

Invoice:
KIVIMAA VILLAGE OF
MOONLIGHT BAY
BOX 120
LIVELONG, SK
S0M 1J0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-845-3336

Emailed results to: rvkmb@myaccess.ca

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:

Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5

Total Fees (including GST)	23.00
Tax Summary G.S.T. (reg # 89583 0180 RT001)	1.10
Amount Received: (Mastercard)	23.00
Balance	**$0.00**

Refund to be issued by the Department of Finance.

Contact Us:
Result Interpretation: Please contact your Prairie North Public Health Officer at: (306) 446-6400
Billing Inquiries: Phone: (306) 766-5832, Email: corpFinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: Total Chlorine: Turbidity: